

**Part III Form 2  
Section 11. ANNUAL REPORT.**

<b>Drinking-Water System Number:</b>	<b>260001013</b>
<b>Drinking-Water System Name:</b>	Baxter Well Supply System
<b>Drinking-Water System Owner:</b>	Corporation of the Township of Essa
<b>Drinking-Water System Category:</b>	Small Municipal Residential
<b>Period being reported:</b>	January 1, 2006 – December 31, 2006

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [ ] No [ X ]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [ X ] No [ ]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px; margin-top: 10px;">                 Essa Municipal Office                  5786 Simcoe Rd. 21                  Utopia, Essa Twp, On. L0M 1T0                  Website: www.essatownship.on.ca             </div>	<p><b><u>Complete for all other Categories.</u></b></p> <p>Number of Designated Facilities served:  <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve?                  Yes [ ] No [ ]</p> <p>Number of Interested Authorities you report to: <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility?                  Yes [ ] No [ ]</p>
--	--

**Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report**

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
Not applicable	Not applicable

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?  
 Yes [ ] No [ NA ]

**Indicate how you notified system users that your annual report is available, and is free of charge.**

- Public access/notice via the web**  
 **Public access/notice via Government Office**  
 **Public access/notice via a newspaper**  
 **Public access/notice via Public Request**  
 **Public access/notice via a Public Library**  
 **Public access/notice via other method**

**Describe your Drinking-Water System**

**Raw Water Supply**

The Baxter well supply system pumphouse is located on Marshall Crescent in the Hamlet of Baxter, Essa Township. Raw water is supplied from two 150mm diameter steel cased drilled wells. Well # 1 is situated 40 m east of the pump house extending to a depth of 64.0m with a rated capacity of 4L/sec at a Total Dynamic Head (TDH) of 86.56m. Well #2 is located 55m east of the pumphouse extending to a depth of 61.0m with a rated capacity of 3.9 L/sec at a TDH of 89m. Both well casings extend 0.7m above the ground surface. Both well heads are enclosed in a concrete crock.

**Disinfection**

Raw water is pumped to the pumphouse via two (2) 75mm lines, where it is injected with NSF 60 certified 12% Sodium Hypochlorite Solution at the main discharge header. The Sodium Hypochlorite solution is stored in a 100 L day tank and delivered to the system by one (1) of two (2) chemical feed pumps, each having the capability of pumping 3.78 L/hr. Contact time is achieved in a 400mm diameter by 50m long chlorine contact chamber prior to entering the distribution system. The Baxter Well Supply System has a rated capacity of 3.9 l/sec or 255 cubic meters per day.

**Distribution and Storage**

The pumphouse is equipped with Five (5) 454L hydro-pneumatic pressure tanks, which provide storage and help to maintain pressure in the distribution system.

**Monitoring**

The Baxter Well Supply System is equipped with on-line Turbidity, Free and Total Chlorine analyzers. Flow and process data is recorded on an SM1000 data logger. The recorded data is down loaded periodically and stored on the main server at the Wasaga Beach office. The system is alarmed for a number of parameters and monitored by Huronia Alarms, Midland, Ontario.

**Auxiliary Power**

The Baxter Well Supply System is equipped with a 35 kw generator and auto switch over to provide stand by power in the event of a power failure.

**List all water treatment chemicals used over this reporting period**

Sodium Hypochlorite 12% Solution NSF, Disinfection

**Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment

**Please provide a brief description and a breakdown of monetary expenses incurred**

No significant expenses incurred in the 2006 reporting period.

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
May 29, 2006	Total Coliform	3	CFU /100 ml	Oral and Written Notification and Resample	May 31, 2006
June 19, 2006	Total Coliform	30	CFU /100 ml	Oral and Written Notification and Resample	June 21, 2006
August 15, 2006	Total Coliform	25	CFU /100 ml	Oral and Written Notification and Resample	August 17, 2006

**Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
RW1 - Raw Water Well #1	Refer to attached Appendix A				
RW2 - Raw Water Well #2					
TW - Treated Water					
DW - Distribution Water					

**Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.**

	Number of Grab Samples	Range of Results (min #)-(max #)
<b>Raw Turbidity</b>		
Well #1	12	0.27 – 0.71 NTU
Well #2	12	0.20 – 0.89 NTU
<b>Treated Turbidity</b>	8760	0 - 1.02 NTU
<b>Treated Free Chlorine</b>	8760	0 – 4.98 mg/L *
<b>Free Chlorine Residual Distribution System</b>	307	0.24 – 2.24 mg/L
<b>Fluoride</b> (If the DWS provides fluoridation)	NA	NA

*NOTE: For continuous monitors use 8760 as the number of samples.*

\* Chlorine residuals of 0.0 and > 4.0 due to system maintenance and / or power failure.

*NOTE: Record the unit of measure if it is **not** milligrams per litre.*

**Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
COA November 9, 2006 # 9596-6UGGWW	Ammonia	Weekly	Raw Well #1 Min: 0.54 Max: 3.22  Raw Well #2 Min: 0.60 Max: 3.76	mg/L

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Refer to attached Appendix A			
Arsenic				
Barium				
Boron				
Cadmium				
Chromium				
Lead				
Mercury				
Selenium				
Sodium				
Uranium				
Fluoride				
Nitrite				
Nitrate				

**Summary of Organic parameters sampled during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Refer to attached Appendix A			
Aldicarb				
Aldrin + Dieldrin				
Atrazine + N-dealkylated metabolites				
Azinphos-methyl				
Bendiocarb				
Benzene				
Benzo(a)pyrene				
Bromoxynil				
Carbaryl				
Carbofuran				
Carbon Tetrachloride				
Chlordane (Total)				
Chlorpyrifos				
Cyanazine				
Diazinon				
Dicamba				
1,2-Dichlorobenzene				
1,4-Dichlorobenzene				
Dichlorodiphenyltrichloroethane (DDT) + metabolites				
1,2-Dichloroethane				
1,1-Dichloroethylene (vinylidene chloride)				
Dichloromethane				

2-4 Dichlorophenol
2,4-Dichlorophenoxy acetic acid (2,4-D)
Diclofop-methyl
Dimethoate
Dinoseb
Diquat
Diuron
Glyphosate
Heptachlor + Heptachlor Epoxide
Lindane (Total)
Malathion
Methoxychlor
Metolachlor
Metribuzin
Monochlorobenzene
Paraquat
Parathion
Pentachlorophenol
Phorate
Picloram
Polychlorinated Biphenyls(PCB)
Prometryne
Simazine
THM
(NOTE: show latest annual average)
Temephos
Terbufos
Tetrachloroethylene
2,3,4,6-Tetrachlorophenol
Triallate
Trichloroethylene
2,4,6-Trichlorophenol
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)
Trifluralin
Vinyl Chloride

Refer to attached Appendix A

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

No Parameters exceeded half the standard prescribed in Schedule 2 for the Baxter Well Supply System.

Parameter	Result Value	Unit of Measure	Date of Sample

**(Only if DWS category is large municipal residential, small municipal residential, large municipal non residential, non municipal year round residential, large non municipal non residential)**

APPENDIX A  
ANNUAL SUMMARY (Microbiological, Inorganic & Organic)

Location:

RW1 – Raw Water Well #1  
RW2 – Raw Water Well #2

TW – Treated Water

DW – Distribution Water

**ANNUAL REPORT - Microbiological, Inorganic & Organic**

Waterworks: 5662 - [260001013] Essa (Baxter) Water Well & Distribution System  
 Period being reported: 01/01/2006 to 12/31/2006

**Microbiological testing done under Schedule 10, 11 or 12 of Regulation 170/03 during this reporting Period**

Location	Number of Samples	Range of E.Coli or Fecal Results (min #) - (max #)	Range of Total Coliform Results (min #) - (max #)	Number of HPC Samples	Range of HPC Results (min #) - (max #)	Number of Background Samples	Range of Background Results (min #) - (max #)
Raw - RW1	52	0 - 0	0 - 17	1	0 - 0	1	0 - 0
Raw - RW2	52	0 - 0	0 - 6	1	3 - 3	1	0 - 0
Treated - TW	55	0 - 0	0 - 30	55	0 - 64	2	0 - 0
Distribution - DW	55	0 - 0	0 - 0	55	0 - 11	2	0 - 0

**Summary of Inorganic parameters tested during this reporting period or most recent**

Parameter	Sample Date	Result Value	Exceedance
Antimony: Sb (ug/L) - TW	2006/01/16	< 1.00	No
Arsenic: As (ug/L) - TW	2006/01/16	< 1.00	No
Barium: Ba (ug/L) - TW	2006/01/16	69.00	No
Boron: B (ug/L) - TW	2006/01/16	44.00	No
Cadmium: Cd (ug/L) - TW	2006/01/16	< 0.10	No
Chromium: Cr (ug/L) - TW	2006/01/16	< 5.00	No
Lead: Pb (ug/L)	2006/01/16	< 0.50	No
Mercury: Hg (ug/L) - TW	2006/01/16	< 0.0001	No
Selenium: Se (ug/L) - TW	2006/01/16	< 2.00	No
Sodium: Na (mg/L) - TW	2003/08/26	17.90	No
Uranium: U (ug/L) - TW	2006/01/16	< 0.10	No
Fluoride Residual: Mean (mg/L) - TW	2003/08/26	0.12	No
Nitrite (mg/L) - TW	2006/01/16	0.010	No
Nitrite (mg/L) - TW	2006/04/04	0.0050	No
Nitrite (mg/L) - TW	2006/07/10	0.0050	No
Nitrite (mg/L) - TW	2006/10/10	0.0050	No
Nitrate (mg/L) - TW	2006/01/16	0.10	No
Nitrate (mg/L) - TW	2006/04/04	0.013	No
Nitrate (mg/L) - TW	2006/07/10	0.013	No
Nitrate (mg/L) - TW	2006/10/10	0.013	No

**ANNUAL REPORT - Microbiological, Inorganic & Organic**

Waterworks: 5662 - [260001013] Essa (Baxter) Water Well & Distribution System  
 Period being reported: 01/01/2006 to 12/31/2006

**Summary of Organic parameters sampled during this reporting period or most recent**

Parameter	Sample Date	Result Value	Exceedance
Alachlor (ug/L) - TW	2006/01/16	< 0.50	No
Aldicarb (ug/L) - TW	2006/01/16	< 5.00	No
Aldrin + Dieldrin (ug/L) - TW	2006/01/16	< 0.012	No
Atrazine + N-dealkylated metabolites (ug/L) - TW	2006/01/16	< 1.00	No
Azinphos-methyl (ug/L) - TW	2006/01/16	< 2.00	No
Bendiocarb (ug/L) - TW	2006/01/16	< 2.00	No
Benzene (ug/L) - TW	2006/01/16	< 0.10	No
Benzo(a)pyrene (ug/L) - TW	2006/01/16	< 0.0090	No
Bromoxynil (ug/L) - TW	2006/01/16	< 0.50	No
Carbaryl (ug/L) - TW	2006/01/16	< 5.00	No
Carbofuran (ug/L) - TW	2006/01/16	< 5.00	No
Carbon Tetrachloride (ug/L) - TW	2006/01/16	< 0.10	No
Chlordane:Total (ug/L) - TW	2006/01/16	< 0.012	No
Chlorpyrifos (ug/L) - TW	2006/01/16	< 1.00	No
Cyanazine (ug/L) - TW	2006/01/16	< 1.00	No
Diazinon (ug/L) - TW	2006/01/16	< 1.00	No
Dicamba (ug/L) - TW	2006/01/16	< 1.00	No
1,2-Dichlorobenzene (ug/L) - TW	2006/01/16	< 0.20	No
1,4-Dichlorobenzene (ug/L) - TW	2006/01/16	< 0.20	No
Dichlorodiphenyltrichloroethane(DDT) + metabolites (ug/L) - TW	2006/01/16	< 0.024	No
1,2-Dichloroethane (ug/L) - TW	2006/01/16	< 0.10	No
1,1-Dichloroethylene (ug/L) - TW	2006/01/16	< 0.10	No
Dichloromethane (ug/L) - TW	2006/01/16	< 0.50	No
2,4-Dichlorophenol (ug/L) - TW	2006/01/16	< 0.50	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (ug/L) - TW	2006/01/16	< 1.00	No
Diclofop-methyl (ug/L) - TW	2006/01/16	< 0.90	No
Dimethoate (ug/L) - TW	2006/01/16	< 2.50	No
Dinoseb (ug/L) - TW	2006/01/16	< 1.00	No
Diquat (ug/L) - TW	2006/01/16	< 7.00	No
Diuron (ug/L) - TW	2006/01/16	< 10.00	No
Glyphosate (ug/L) - TW	2006/01/16	< 10.00	No
Heptachlor+Hepachlor Epoxide (ug/L) - TW	2006/01/16	< 0.012	No
Lindane: (ug/L) - TW	2006/01/16	< 0.0060	No
Malathion (ug/L) - TW	2006/01/16	< 5.00	No
Methoxychlor (ug/L) - TW	2006/01/16	< 0.024	No
Metolachlor (ug/L) - TW	2006/01/16	< 0.50	No
Metribuzin (ug/L) - TW	2006/01/16	< 5.00	No
Monochlorobenzene (ug/L) - TW	2006/01/16	< 0.10	No
Paraquat (ug/L) - TW	2006/01/16	< 1.00	No
Parathion (ug/L) - TW	2006/01/16	< 1.00	No
Pentachlorophenol (ug/L) - TW	2006/01/16	< 0.50	No
Phorate (ug/L) - TW	2006/01/16	< 0.50	No
Picloram (ug/L) - TW	2006/01/16	< 5.00	No
Polychlorinated Bichenysl(PCB) (ug/L) - TW	2006/01/16	< 0.50	No

**ANNUAL REPORT - Microbiological, Inorganic & Organic**

Waterworks: 5662 - [260001013] Essa (Baxter) Water Well & Distribution System

Period being reported: 01/01/2006 to 12/31/2006

Prometryne (ug/L) - TW	2006/01/16	< 0.25	No
Simazine (ug/L) - TW	2006/01/16	< 1.00	No
THM (ug/L)	2006	1.23	No
Temephos (ug/L) - TW	2006/01/16	< 10.00	No
Terbufos (ug/L) - TW	2006/01/16	< 0.70	No
Tetrachloroethylene (ug/L) - TW	2006/01/16	< 0.10	No
2,3,4,6-Tetrachlorophenol (ug/L) - TW	2006/01/16	< 0.50	No
Triallate (ug/L) - TW	2006/01/16	< 1.00	No
Trichloroethylene (ug/L) - TW	2006/01/16	< 0.10	No
2,4,6-Trichlorophenol (ug/L) - TW	2006/01/16	< 0.50	No
2,4,5-Trichlorophenoxy acetic acid (ug/L) - TW	2006/01/16	< 1.00	No
Trifluralin (ug/L) - TW	2006/01/16	< 1.00	No
Vinyl Chloride (ug/L) - TW	2006/01/16	< 0.20	No