



**Ontario Clean Water Agency**  
**Agence Ontarienne Des Eaux**

---

**ANGUS  
WELL SUPPLY SYSTEM**

**ONTARIO REGULATION 170/03**

**Section 11**

**ANNUAL REPORT**

**For the Period of**

**January 1, 2007 to December 31, 2007**

Prepared for The Corporation of the Township of Essa

By the Ontario Clean Water Agency

**Part III Form 2  
Section 11. ANNUAL REPORT.**

<b>Drinking-Water System Number:</b>	<b>260001026</b>
<b>Drinking-Water System Name:</b>	Angus Well Supply System
<b>Drinking-Water System Owner:</b>	The Corporation of the Township of Essa
<b>Drinking-Water System Category:</b>	Large Municipal Residential
<b>Period being reported:</b>	January 1, 2007 – December 31, 2007

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [ ] No [ X ]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [ X ] No [ ]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;">                 Township of Essa Municipal Office                  5786 Simcoe County Road 21                  Utopia, Essa Twp, ON. L0M 1T0                  Website: www.essatownship.on.ca             </div>	<p><b><u>Complete for all other Categories.</u></b></p> <p>Number of Designated Facilities served:  <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ ] No [ ]</p> <p>Number of Interested Authorities you report to: <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ ] No [ ]</p>
--	--

**Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report**

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
Not applicable	Not applicable

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?  
 Yes [ ] No [ NA ]

**Indicate how you notified system users that your annual report is available, and is free of charge.**

- Public access/notice via the web**  
 **Public access/notice via Government Office**  
 **Public access/notice via a newspaper**  
 **Public access/notice via Public Request**  
 **Public access/notice via a Public Library**  
 **Public access/notice via other method**

**Describe your Drinking-Water System**

**The Angus Well Supply System, Treatment and Storage Works serving the Town of Angus includes the Mill Street Water Treatment Plant and the McGeorge Water Treatment Plant. These facilities supply water through a common distribution system.**

**Mill Street Water Treatment Plant**

The Mill Street Water Treatment Plant is located at 28 Mill Street in the Town of Angus. Raw Water is supplied from one 610 mm diameter drilled groundwater well (Well #1) that can provide up to 3927 m<sup>3</sup>/day of a good quality potable water. As groundwater is pumped from the well; chemical feed pumps are automatically activated to add sodium silicate (for iron sequestering) and sodium hypochlorite (for disinfection). Treated water is stored in two underground reservoirs, with a capacity of 2500 m<sup>3</sup> and 902 m<sup>3</sup> respectively. Flow is measured before entering the reservoir and as the treated water enters the distribution system. On-line monitoring equipment continuously monitors chlorine residual, turbidity and flow rates. Flow and process data is recorded on an SM1000 data logger. The recorded data is down loaded periodically and stored on the main server at the Ontario Clean Water Agency office in Wasaga Beach. The system is alarmed for a number of parameters and monitored by Huronia Alarms, Midland, Ontario. This pumphouse is equipped with a 400 kW diesel generator and auto switch over to provide stand by power in the event of a power failure.

**McGeorge Water Treatment Plant**

The McGeorge Water Treatment Plant is located on Essa Side Road 30. Raw Water is supplied from two 203 mm diameter drilled groundwater wells (Well #1 and Well #2) capable of providing up to 2627 m<sup>3</sup>/day potable water. As groundwater flows out of the (artesian) wells, pumps are automatically activated to add sodium silicate (for iron sequestering) and sodium hypochlorite (for disinfection). Treated water is stored in two underground reservoirs with capacities of 95 m<sup>3</sup> and 157 m<sup>3</sup> respectively. On-line monitoring equipment continuously monitors chlorine residual, turbidity and flow rates. Flow and process data is recorded on an SM1000 data logger. The recorded data is down loaded periodically and stored on the main server. The system is alarmed for a number of parameters and monitored by Huronia Alarms, Midland, Ontario. This pumphouse is equipped with a 64 kW diesel generator and auto switch over to provide stand by power in the event of a power failure.

**List all water treatment chemicals used over this reporting period**

Sodium Hypochlorite 12% Solution NSF, Disinfection  
Sodium Silicate, Iron Sequestering, NSF

**Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment

**Please provide a brief description and a breakdown of monetary expenses incurred**

Expenses incurred which were in addition to normal operating costs.

1. Emergency repair to hydrant, curb boxes and water service.
2. Purchase de-chlorination equipment, repair kits for chemical pumps, submersible pump for reservoir cleaning and magnetic locator.
3. Clean reservoir at McGeorge.
4. Purchase new hydrant flags.
5. Purchase fire hydrant flow meters to monitor water taking.

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
July 3, 2007	Total Coliform	1	Count/ 100 ml	Oral and Written Notification and Resample	July 5, 2007

### Microbiological testing done under the Schedule 10 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
RW1 - Raw Water Well #1 McGeorge	Refer to attached Appendix A				
RW2 - Raw Water Well #2 McGeorge					
RW3 - Raw Water Well #1 Mill					
TW1 - Treated Water McGeorge					
TW2 - Treated Water Mill					
DW - Distribution Water					

### Operational testing done under Schedule 7 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Raw Turbidity		
Mill St. Well #1	12	0.18 – 0.52 NTU
McGeorge Well #1	12	0.29 – 0.68 NTU
McGeorge Well #2	12	0.13 – 0.62 NTU
Treated Turbidity		
Mill St.	8760	0.01 – 1.0 NTU
McGeorge	8760	0 – 1.01 NTU
Treated Free Chlorine Residual		
Mill St.	8760	0 – 5.0 mg/L *
McGeorge	8760	0 – 4.91 mg/L *
Free Chlorine Residual Distribution System	680	0.57 – 1.93 mg/L
Fluoride (If the DWS provides fluoridation)	NA	NA

*NOTE: For continuous monitors use 8760 as the number of samples.*

\* Chlorine residuals of 0.0 and > 4.0 due to system maintenance and / or power interruptions.

*NOTE: Record the unit of measure if it is **not** milligrams per litre.*

**Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
No Additional Testing and or Sampling Required				

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Refer to attached Appendix A			
Arsenic				
Barium				
Boron				
Cadmium				
Chromium				
Lead				
Mercury				
Selenium				
Sodium				
Uranium				
Fluoride				
Nitrite				
Nitrate				

**Summary of Organic parameters sampled during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Refer to attached Appendix A			
Aldicarb				
Aldrin + Dieldrin				
Atrazine + N-dealkylated metabolites				
Azinphos-methyl				
Bendiocarb				
Benzene				
Benzo(a)pyrene				
Bromoxynil				
Carbaryl				
Carbofuran				
Carbon Tetrachloride				

<b>Chlordane (Total)</b>
<b>Chlorpyrifos</b>
<b>Cyanazine</b>
<b>Diazinon</b>
<b>Dicamba</b>
<b>1,2-Dichlorobenzene</b>
<b>1,4-Dichlorobenzene</b>
<b>Dichlorodiphenyltrichloroethane (DDT) + metabolites</b>
<b>1,2-Dichloroethane</b>
<b>1,1-Dichloroethylene (vinylidene chloride)</b>
<b>Dichloromethane</b>
<b>2,4 Dichlorophenol</b>
<b>2,4-Dichlorophenoxy acetic acid (2,4-D)</b>
<b>Diclofop-methyl</b>
<b>Dimethoate</b>
<b>Dinoseb</b>
<b>Diquat</b>
<b>Diuron</b>
<b>Glyphosate</b>
<b>Heptachlor + Heptachlor Epoxide</b>
<b>Lindane (Total)</b>
<b>Malathion</b>
<b>Methoxychlor</b>
<b>Metolachlor</b>
<b>Metribuzin</b>
<b>Monochlorobenzene</b>
<b>Paraquat</b>
<b>Parathion</b>
<b>Pentachlorophenol</b>
<b>Phorate</b>
<b>Picloram</b>
<b>Polychlorinated Biphenyls(PCB)</b>
<b>Prometryne</b>
<b>Simazine</b>
<b>THM</b> (NOTE: show latest annual average)
<b>Temephos</b>
<b>Terbufos</b>
<b>Tetrachloroethylene</b>
<b>2,3,4,6-Tetrachlorophenol</b>
<b>Triallate</b>
<b>Trichloroethylene</b>
<b>2,4,6-Trichlorophenol</b>
<b>2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)</b>
<b>Trifluralin</b>
<b>Vinyl Chloride</b>

Refer to attached Appendix A

**List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.**

No Parameters exceeded half the standard prescribed in Schedule 2 for the Angus Well Supply System.

Parameter	Result Value	Unit of Measure	Date of Sample

**(Only if DWS category is large municipal residential, small municipal residential, large municipal non residential, non municipal year round residential, large non municipal non residential)**

**APPENDIX A**  
**ANNUAL SUMMARY (Microbiological, Inorganic & Organic)**

**Location:**

RW1 – Raw Water Well #1 McGeorge

RW2 – Raw Water Well #2 McGeorge

RW3 – Raw Water Well #1 Mill

TW1 – Treated Water McGeorge

TW2 – Treated Water Mill

DW – Distribution Water

**ANNUAL REPORT - Microbiological, Inorganic & Organic**

Waterworks: 6065 - [260001026] Angus Well Supply System

Period being reported: 01/01/2007 to 12/31/2007

**Microbiological testing done under Schedule 10 of Regulation 170/03 during this reporting Period**

Location	Number of Samples	Range of E.Coli or Fecal Results (min #) - (max #)	Range of Total Coliform Results (min #) - (max #)	Number of HPC Samples	Range of HPC Results (min #) - (max #)	Number of Background Samples	Range of Background Results (min #) - (max #)
Raw - RW1	52	0 - 0	0 - 0		-		-
Raw - RW2	52	0 - 0	0 - 0		-		-
Raw - RW3	52	0 - 0	0 - 0		-		-
Treated - TW1	52	0 - 0	0 - 0	52	0 - 520		-
Treated - TW2	52	0 - 0	0 - 0	52	0 - 2000		-
Distribution - DW	215	0 - 0	0 - 1	59	0 - 820		-

**Summary of Inorganic parameters tested during this reporting period or most recent**

Parameter	Sample Date	Result Value	Exceedance
Antimony: Sb (ug/L) - TW1	2006/01/17	< 1.00	No
Antimony: Sb (ug/L) - TW2	2006/01/17	< 1.00	No
Arsenic: As (ug/L) - TW1	2006/01/17	< 1.00	No
Arsenic: As (ug/L) - TW2	2006/01/17	< 1.00	No
Barium: Ba (ug/L) - TW1	2006/01/17	0.090	No
Barium: Ba (ug/L) - TW2	2006/01/17	0.16	No
Boron: B (ug/L) - TW1	2006/01/17	0.030	No
Boron: B (ug/L) - TW2	2006/01/17	0.030	No
Cadmium: Cd (ug/L) - TW1	2006/01/17	< 0.10	No
Cadmium: Cd (ug/L) - TW2	2006/01/17	< 0.010	No
Chromium: Cr (ug/L) - TW1	2006/01/17	< 5.00	No
Chromium: Cr (ug/L) - TW2	2006/01/17	< 5.00	No
Lead: Pb (ug/L)	2007/06/07	0.55	No
Mercury: Hg (ug/L) - TW1	2006/01/17	0	No
Mercury: Hg (ug/L) - TW2	2006/01/17	0	No
Selenium: Se (ug/L) - TW1	2006/01/17	< 2.00	No
Selenium: Se (ug/L) - TW2	2006/01/17	< 2.00	No
Sodium: Na (mg/L) - TW1	2003/08/25	20.70	Yes
Sodium: Na (mg/L) - TW2	2003/08/25	22.40	Yes
Uranium: U (ug/L) - TW1	2006/01/17	< 0.10	No
Uranium: U (ug/L) - TW2	2006/01/17	< 0.10	No
Fluoride Residual: Mean (mg/L) - TW1	2003/08/25	0.12	No
Fluoride Residual: Mean (mg/L) - TW2	2003/08/25	0.10	No
Nitrite (mg/L) - TW1	2007/01/09	0.0050	No
Nitrite (mg/L) - TW1	2007/04/03	0.0050	No
Nitrite (mg/L) - TW1	2007/07/03	0.0050	No
Nitrite (mg/L) - TW1	2007/10/02	0.0050	No
Nitrite (mg/L) - TW2	2007/01/09	0.0050	No
Nitrite (mg/L) - TW2	2007/04/03	0.0050	No
Nitrite (mg/L) - TW2	2007/07/03	0.0050	No
Nitrite (mg/L) - TW2	2007/10/02	0.0050	No
Nitrate (mg/L) - TW1	2007/01/09	0.025	No
Nitrate (mg/L) - TW1	2007/04/03	0.013	No
Nitrate (mg/L) - TW1	2007/07/03	0.028	No
Nitrate (mg/L) - TW1	2007/10/02	0.024	No
Nitrate (mg/L) - TW2	2007/01/09	0.013	No
Nitrate (mg/L) - TW2	2007/04/03	0.013	No
Nitrate (mg/L) - TW2	2007/07/03	0.013	No
Nitrate (mg/L) - TW2	2007/10/02	0.013	No

**Summary of Organic parameters sampled during this reporting period or most recent**

Parameter	Sample Date	Result Value	Exceedance
Alachlor (ug/L) - TW1	2006/01/17	< 0.50	No
Alachlor (ug/L) - TW2	2006/01/17	< 0.50	No
Aldicarb (ug/L) - TW1	2006/01/17	< 5.00	No
Aldicarb (ug/L) - TW2	2006/01/17	< 5.00	No

**ANNUAL REPORT - Microbiological, Inorganic & Organic**

Waterworks: 6065 - [260001026] Angus Well Supply System

Period being reported: 01/01/2007 to 12/31/2007

Parameter	Sample Date	Result Value	Exceedance
Aldrin + Dieldrin (ug/L) - TW1	2006/01/17	< 0.012	No
Aldrin + Dieldrin (ug/L) - TW2	2006/01/17	< 0.012	No
Atrazine + N-dealkylated metabolites (ug/L) - TW1	2006/01/17	< 1.00	No
Atrazine + N-dealkylated metabolites (ug/L) - TW2	2006/01/17	< 1.00	No
Azinphos-methyl (ug/L) - TW1	2006/01/17	< 2.00	No
Azinphos-methyl (ug/L) - TW2	2006/01/17	< 2.00	No
Bendiocarb (ug/L) - TW1	2006/01/17	< 2.00	No
Bendiocarb (ug/L) - TW2	2006/01/17	< 2.00	No
Benzene (ug/L) - TW1	2006/01/17	< 0.10	No
Benzene (ug/L) - TW2	2006/01/17	< 0.10	No
Benzo(a)pyrene (ug/L) - TW1	2006/01/17	< 0.0090	No
Benzo(a)pyrene (ug/L) - TW2	2006/01/17	< 0.0090	No
Bromoxynil (ug/L) - TW1	2006/01/17	< 0.50	No
Bromoxynil (ug/L) - TW2	2006/01/17	< 0.50	No
Carbaryl (ug/L) - TW1	2006/01/17	< 5.00	No
Carbaryl (ug/L) - TW2	2006/01/17	< 5.00	No
Carbofuran (ug/L) - TW1	2006/01/17	< 5.00	No
Carbofuran (ug/L) - TW2	2006/01/17	< 5.00	No
Carbon Tetrachloride (ug/L) - TW1	2006/01/17	< 0.10	No
Carbon Tetrachloride (ug/L) - TW2	2006/01/17	< 0.10	No
Chlordane:Total (ug/L) - TW1	2006/01/17	< 0.012	No
Chlordane:Total (ug/L) - TW2	2006/01/17	< 0.012	No
Chlorpyrifos (ug/L) - TW1	2006/01/17	< 1.00	No
Chlorpyrifos (ug/L) - TW2	2006/01/17	< 1.00	No
Cyanazine (ug/L) - TW1	2006/01/17	< 1.00	No
Cyanazine (ug/L) - TW2	2006/01/17	< 1.00	No
Diazinon (ug/L) - TW1	2006/01/17	< 1.00	No
Diazinon (ug/L) - TW2	2006/01/17	< 1.00	No
Dicamba (ug/L) - TW1	2006/01/17	< 1.00	No
Dicamba (ug/L) - TW2	2006/01/17	< 1.00	No
1,2-Dichlorobenzene (ug/L) - TW1	2006/01/17	< 0.10	No
1,2-Dichlorobenzene (ug/L) - TW2	2006/01/17	< 0.20	No
1,4-Dichlorobenzene (ug/L) - TW1	2006/01/17	< 0.20	No
1,4-Dichlorobenzene (ug/L) - TW2	2006/01/17	< 0.20	No
Dichlorodiphenyltrichloroethane(DDT) + metabolites (ug/L) - TW1	2006/01/17	< 0.024	No
Dichlorodiphenyltrichloroethane(DDT) + metabolites (ug/L) - TW2	2006/01/17	< 0.024	No
1,2-Dichloroethane (ug/L) - TW1	2006/01/17	< 0.10	No
1,2-Dichloroethane (ug/L) - TW2	2006/01/17	< 0.10	No
1,1-Dichloroethylene (ug/L) - TW1	2006/01/17	< 0.10	No
1,1-Dichloroethylene (ug/L) - TW2	2006/01/17	< 0.10	No
Dichloromethane (ug/L) - TW1	2006/01/17	< 0.50	No
Dichloromethane (ug/L) - TW2	2006/01/17	< 0.50	No
2,4-Dichlorophenol (ug/L) - TW1	2006/01/17	< 0.50	No
2,4-Dichlorophenol (ug/L) - TW2	2006/01/17	< 0.50	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (ug/L) - TW1	2006/01/17	< 1.00	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (ug/L) - TW2	2006/01/17	< 1.00	No
Diclofop-methyl (ug/L) - TW1	2006/01/17	< 0.90	No
Diclofop-methyl (ug/L) - TW2	2006/01/17	< 0.90	No
Dimethoate (ug/L) - TW1	2006/01/17	< 2.50	No
Dimethoate (ug/L) - TW2	2006/01/17	< 2.50	No
Dinoseb (ug/L) - TW1	2006/01/17	< 1.00	No
Dinoseb (ug/L) - TW2	2006/01/17	< 1.00	No
Diquat (ug/L) - TW1	2006/01/17	< 7.00	No
Diquat (ug/L) - TW2	2006/01/17	< 7.00	No
Diuron (ug/L) - TW1	2006/01/17	< 10.00	No
Diuron (ug/L) - TW2	2006/01/17	< 10.00	No
Glyphosate (ug/L) - TW1	2006/01/17	< 10.00	No
Glyphosate (ug/L) - TW2	2006/01/17	< 10.00	No
Heptachlor+Hepachlor Epoxide (ug/L) - TW1	2006/01/17	< 0.012	No
Heptachlor+Hepachlor Epoxide (ug/L) - TW2	2006/01/17	< 0.012	No
Lindane: (ug/L) - TW1	2006/01/17	< 0.0060	No
Lindane: (ug/L) - TW2	2006/01/17	< 0.0060	No
Malathion (ug/L) - TW1	2006/01/17	< 5.00	No
Malathion (ug/L) - TW2	2006/01/17	< 5.00	No
Methoxychlor (ug/L) - TW1	2006/01/17	< 0.024	No
Methoxychlor (ug/L) - TW2	2006/01/17	< 0.024	No
Metolachlor (ug/L) - TW1	2006/01/17	< 0.50	No
Metolachlor (ug/L) - TW2	2006/01/17	< 0.50	No
Metribuzin (ug/L) - TW1	2006/01/17	< 5.00	No
Metribuzin (ug/L) - TW2	2006/01/17	< 5.00	No

**ANNUAL REPORT - Microbiological, Inorganic & Organic**

Waterworks: 6065 - [260001026] Angus Well Supply System

Period being reported: 01/01/2007 to 12/31/2007

Parameter	Sample Date	Result Value	Exceedance
Monochlorobenzene (ug/L) - TW1	2006/01/17	< 0.10	No
Monochlorobenzene (ug/L) - TW2	2006/01/17	< 0.10	No
Paraquat (ug/L) - TW1	2006/01/17	< 1.00	No
Paraquat (ug/L) - TW2	2006/01/17	< 1.00	No
Parathion (ug/L) - TW1	2006/01/17	< 1.00	No
Parathion (ug/L) - TW2	2006/01/17	< 1.00	No
Pentachlorophenol (ug/L) - TW1	2006/01/17	< 0.50	No
Pentachlorophenol (ug/L) - TW2	2006/01/17	< 0.50	No
Phorate (ug/L) - TW1	2006/01/17	< 0.50	No
Phorate (ug/L) - TW2	2006/01/17	< 0.50	No
Picloram (ug/L) - TW1	2006/01/17	< 5.00	No
Picloram (ug/L) - TW2	2006/01/17	< 5.00	No
Polychlorinated Bichenysl(PCB) (ug/L) - TW1	2006/01/17	< 0.050	No
Polychlorinated Bichenysl(PCB) (ug/L) - TW2	2006/01/17	< 0.050	No
Prometryne (ug/L) - TW1	2006/01/17	< 0.25	No
Prometryne (ug/L) - TW2	2006/01/17	< 0.25	No
Simazine (ug/L) - TW1	2006/01/17	< 1.00	No
Simazine (ug/L) - TW2	2006/01/17	< 1.00	No
THM (ug/L)	2007	27.25	No
Temephos (ug/L) - TW1	2006/01/17	< 10.00	No
Temephos (ug/L) - TW2	2006/01/17	< 10.00	No
Terbufos (ug/L) - TW1	2006/01/17	< 0.70	No
Terbufos (ug/L) - TW2	2006/01/17	< 0.70	No
Tetrachloroethylene (ug/L) - TW1	2006/01/17	< 0.10	No
Tetrachloroethylene (ug/L) - TW2	2006/01/17	< 0.10	No
2,3,4,6-Tetrachlorophenol (ug/L) - TW1	2006/01/17	< 0.50	No
2,3,4,6-Tetrachlorophenol (ug/L) - TW2	2006/01/17	< 0.50	No
Triallate (ug/L) - TW1	2006/01/17	< 1.00	No
Triallate (ug/L) - TW2	2006/01/17	< 1.00	No
Trichloroethylene (ug/L) - TW1	2006/01/17	< 0.10	No
Trichloroethylene (ug/L) - TW2	2006/01/17	< 0.10	No
2,4,6-Trichlorophenol (ug/L) - TW1	2006/01/17	< 0.50	No
2,4,6-Trichlorophenol (ug/L) - TW2	2006/01/17	< 0.50	No
2,4,5-Trichlorophenoxy acetic acid (ug/L) - TW1	2006/01/17	< 1.00	No
2,4,5-Trichlorophenoxy acetic acid (ug/L) - TW2	2006/01/17	< 1.00	No
Trifluralin (ug/L) - TW1	2006/01/17	< 1.00	No
Trifluralin (ug/L) - TW2	2006/01/17	< 1.00	No
Vinyl Chloride (ug/L) - TW1	2006/01/17	< 0.20	No
Vinyl Chloride (ug/L) - TW2	2006/01/17	< 0.20	No