

	Public Notification of Bypass, Overflow and Spill Events	Issued: 2021-08-21 Rev.: 0 Pages: 1 of 1
Angus Waste Pollution Control Plant		

Purpose

This notification has been prepared in accordance with Environmental Compliance Approval 7826-BRPRAW issued September 11, 2020 for the Angus Water Pollution Control Plant. The purpose of this procedure is to notify the Public and Downstream Users that may be impacted by an overflow, bypass or spill event.

Details

Location:	Angus WPCP 147 Centre Street, Angus, ON
Type of Event:	X Overflow <input type="checkbox"/> Bypass <input type="checkbox"/> Spill
Start Date & Time:	December 23 rd , 2022 at 2137hrs
End Date & Time:	December 24 th , 2022 at 0800hrs
Total Discharge Volume (m³):	686m ³
Cause of the Event:	<p style="text-align: center;"> A weather event caused a power outage at the Angus WPCP. The outage caused a power failure to the secondary effluent pumps. The failed pumps in the secondary wet well did not pump causing the wet well to overflow and spill into the final effluent pit. </p>

If there are any questions or concerns regarding this notification, please contact the Ontario Clean Water Agency at 705-429-2525 during regular office hours of Monday to Friday, 8:15AM to 4:00PM.